


Number	18-002719-PR01 (NW 5.0-H05-04-en-01)
Owner	TPI All Seasons Co. Ltd. 26/56 Chan Tad Mai Road, Tungmahamek 10120 Khet Sathorn, Bangkok Thailand
Product	LSG
Designation	Shipping name:  <b>VISTASAFE™ VS103 Structure 88.2</b>
Details	Manufacturer TPI All Seasons Co. Ltd., - Khet Sathorn, Bangkok; Overall dimensions (W x H) 1230 mm x 1480 mm; Glass configuration Float 8 mm / VISTASAFE VS103 0.76 mm / Float 8 mm; Thickness 16.1 mm; Surface weight 39.7 kg/m <sup>2</sup>
Special features	
Result	

Weighted Sound Reduction Index  $R_w$  and Spectrum-Adaptation Terms  $C$  and  $C_{tr}$  according to EN ISO 10140-2:2010-09, EN ISO 717-1:2013-03




**$R_w (C; C_{tr}) = 39 (-1; -2) \text{ dB}$**

#### Basis \*)

EN ISO 10140-2:2010-09  
EN ISO 717-1:2013-03  
EN ISO 10140-1:2016-08  
\*) and corresponding national versions (e.g. DIN EN)  
Test report: 18-002719-PR01 PB 5.0-H05-04-en-01

#### Representation



#### Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

#### Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

#### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim  
21.08.2019



Dr. Joachim Hessinger, Dipl.-Phys.  
Head of Testing Department  
Building Acoustics



Stefan Bacher, Dipl.-Ing. (FH)  
Operating Testing Officer  
Building Acoustics

#### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 57D-FC649